

**City of Avondale Estates**  
**Historic Preservation Commission**  
**COA Application Review\***

**March 2, 2026 HPC Meeting**

---

**Applicant:** Samuel Rowland

**Property Address:** 21 Kensington Road

**Property Type:** Residential, Preservation Designation

**Project Summary:** The proposed project for this 1926 English Vernacular Revival House consists of (1) renovation of the mudroom at the house's rear corner; (2) construction of a new deck at the mudroom entrance on the house's rear elevation; and (3) replacement of the rear-elevation basement door. *Replacement windows for the house's upper floor were approved by the HPC in November 2022. Construction of a new freestanding garage/accessory dwelling unit with a composite-material deck was approved by the HPC in January 2025.*

**Applicable Guidelines:** *Historic District Guidelines, Preservation Designation Properties – Porches, p. 26; Entrances, p. 27; Windows, pp. 28-29; Materials, p. 35.*

**Analysis:** The project proposes to (1) renovate the mudroom at the house's rear corner. The existing mudroom appears to be a previously enclosed porch that is located along the house's rear and side elevations and is under the house's main roof. The former porch is enclosed with single sheets of beaded board wood panels and pairs of 4-over-4, double-hung windows between square wood support posts. A rear entrance door is located on the rear-elevation side of the porch at a set of masonry steps leading down to grade. Proposed renovations include replacement of the beaded board panels with standard 2x4 wall framing between the existing support posts to allow space for wall insulation and electrical conduit. The walls will be finished on the exterior with fiber-cement siding in either a horizontally lapped, tongue-and-groove, or panel design. Existing windows will be replaced with wood, 6-over-1, double-hung, simulated divided light (SDL) windows that match the house's upper-floor replacement windows approved by the HPC in November 2022. The existing rear entrance door opening will be relocated along the same wall to the position of the adjacent wall/window panel, and the wall/window panel will move to the position of the door in order to align the rear entrance door with an interior door for better traffic flow. The wood-paneled and glass rear entrance door will be replaced with a more secure fiberglass door. The existing masonry steps will be removed.

The project also proposes to (2) construct a new deck at the mudroom entrance on the house's rear elevation. The deck will measure approximately 20' by 20' and will extend approximately 3' past the house's rear corner to the 10' setback at the side property line. The deck's decking, railing, and steps will be constructed of the same composite materials as the deck on the rear of the new garage/accessory dwelling unit approved by the HPC in January 2025. The existing

masonry steps at the mudroom entrance will be removed. The existing fence along the side property line may have to be relocated slightly to accommodate the deck's extension past the house's rear corner.

The project also proposes to (3) replace the rear-elevation basement door. The house's existing wood and glass basement door is thought to be a replacement door and is reported to be in poor condition. According to the application, the door has been previously cut to accommodate a drainage pipe. The door will be replaced with a more secure fiberglass door that will match the new mudroom entrance door.

The *Historic District Guidelines for Porches on Preservation Designation* properties state that side porches may be enclosed with glazing or screening, maintaining any historic elements, and that rear porches may be enclosed or removed for additions. New porches are limited to the rear or rear half of the side elevations. Lot coverage shall not exceed 40% of the total lot.

This porch, which is part of both the rear elevation and rear half of the side elevation and, therefore, visible from the street, is original to the house's construction but appears to have been enclosed with the current materials at a later date. As such, the porch and its current enclosure may be seen as a historic element of the house. A new enclosure of this rear- and side-elevation porch is allowed by the guidelines. When enclosing this porch with new materials to improve insulation and usability, the existing materials and appearance of the porch should be respected. Replacement materials should be wood because this porch is part of the original house (see *Guidelines for Materials* below) and to help maintain the porch's historic appearance. Exterior siding should be wood in a panel design that looks similar to the existing beaded board panels. Windows in a 4-over-4 pattern rather than a 6-over-1 pattern should be considered to help maintain the porch's historic appearance and distinguish them from other windows in the house.

The addition of a new deck is allowed on the house's rear elevation (see *Guidelines for Materials* below). Removal of the masonry steps is also allowed due to their location at the rear elevation. The additional 400 SF of the new deck minus the rear steps and concrete landing brings the total lot coverage to 34.6%.

The *Historic District Guidelines for Entrances on Preservation Designation* properties state that replacement doors at the rear of a structure may be of a modern design. The existing mudroom door and basement door, identified as a replacement door, may be replaced with doors of a different design than the existing doors because they are on the rear elevation. However, the doors should be wood rather than fiberglass since they are located on original portions of the house (see *Guidelines for Materials* below).

The *Historic District Guidelines for Windows on Preservation Designation* properties state that all attempts should be made to protect, maintain, and repair original historic windows. When windows are determined to be beyond repair, replacement is allowed. Replacement windows shall match the original windows in dimension, design, and material. They may use double-pane

glass and have true divided lights (TDLs) or simulated divided lights (SDLs). SDLs must include the spacer between the glass at each muntin.

The porch's 4-over-4, double-hung wood windows are not original but may be considered historic elements. Replacement windows should be wood as proposed. The use of 4-over-4 sash instead of 6-over-1 should be considered to help maintain the porch's historic appearance.

The *Historic District Guidelines for Materials on Preservation Designation* properties state that no new synthetic materials may be used on the original portions of Preservation Designation properties. Repair all components with the same material.

Since the porch is an original part of the house and its existing features may be considered historic elements, finish materials such as synthetic fiber-cement siding and fiberglass doors are not allowed on this original portion of the house. Replacement materials should be wood to match the existing historic materials. The use of composite materials for the new deck is acceptable because the deck is a new addition to the original house and is on the house's rear elevation.

**Recommendation:** Based on the *Historic District Guidelines for Preservation Designation* properties, the proposed project is recommended with the following stipulations:

- New enclosure materials on the porch should be wood rather than a synthetic material such as fiber-cement.
- Respect the porch's existing historic elements by using panels with a similar appearance to the beaded board panels and by considering the use of 4-over-4, double-hung, wood windows rather than 6-over-1.
- New rear entrance and basement doors should be wood rather than a synthetic material such as fiberglass.

---

\*Reviewed by WLA Studio. This review is based on materials received by the applicant at the time of review. New information from the applicant and/or a site visit to the subject property may amend the recommendation.

# Historic Preservation Commission Application for Certificate of Appropriateness COA



21 North Avondale Plaza  
Avondale Estates, Georgia 30002  
Ph: (404) 294-5400  
Fx: (404) 299-8137  
[www.avondaleestates.org](http://www.avondaleestates.org)

## APPLICANT INFORMATION

|                                                                                                                                                                                                   |                                                                        |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------|
| Applicant Name:<br>Samuel Rowland                                                                                                                                                                 | Address/City/Zip Code:<br>21 Kensington Rd, Avondale Estates GA, 30002 |
| Phone:<br>[REDACTED]                                                                                                                                                                              | Email:<br>[REDACTED]                                                   |
| Project Address:<br>21 Kensington Rd, Avondale Estates GA, 30002                                                                                                                                  |                                                                        |
| <b>If applicant is representing homeowner at the meeting, a notarized statement from the homeowner must be submitted with the application giving applicant permission to represent homeowner.</b> |                                                                        |
| Applicant Signature:<br>                                                                                                                                                                          | Date:<br>2/6/2026                                                      |

**PROPOSED PROJECT:** ☐Residential ☐Commercial

**New Construction** ☐ **Renovation/Repair** ☒ **Demolition** ☐

Description of Project:  
Renovation of the mudroom located at the rear corner of the residence and addition of a deck in the rear yard located outside the rear-facing mudroom entry door

## ATTACHMENTS (Refer to attached checklist for further details)

- ☐ Site plan and scaled drawings of the proposed changes  
(Dimensioned site plan, Dimensioned floor plan(s), Material Samples, Material Details, Color Samples, Street Elevation, Side Elevation).
- ☐ A detailed narrative of the proposed project.
- ☐ Materials checklist with all materials including windows and door changes.
- ☐ Sample photos of windows, doors, and garage doors (if applicable).
- ☐ Photos of the structure site to be modified.
- ☐ Photos of the structure as seen from the street.
- ☐ Electronic copy of application packet must be submitted to: [lleland@avondaleestates.org](mailto:lleland@avondaleestates.org)

Comments:

**Application will be reviewed by the Avondale Estates Historic Preservation Commission and  
Approved or Denied within 45 days of the submittal date**

## FOR OFFICE USE ONLY

| DATE APPLICATION<br>SUBMITTED: | APPLICATION<br>RECEIVED BY: | TIER DESIGNATION<br><input type="checkbox"/> Preservation <input type="checkbox"/> Adaptation<br><input type="checkbox"/> Conservation<br><input type="checkbox"/> Construction | HPC MEETING<br>DATE FOR<br>APPLICATION: | PARCEL ID# |
|--------------------------------|-----------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------|------------|
|--------------------------------|-----------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------|------------|

## Project: 2026 Rowland Residence Rear Mudroom & Deck

### Project summary

The below provides a detailed description of the proposed renovation of the mudroom located at the rear corner of the residence and the proposed addition of a deck in the rear yard located out the rear-facing mudroom entry door. All exterior work proposed will impact only the back half of the property which is not visible from the street.


### Project description

The existing mudroom is constructed of materials and of construction methods inconsistent with the remainder of the house. We expect that the mudroom may have been built as an enclosed porch and later finished in roughly. Exterior walls are only single panels of beadboard without any framed wall cavity to allow for insulation, electrical, etc. Windows are inoperable and inconsistent in design with other windows on the house. The floor has a significant slant that may reflect initial porch design for shedding water. And masonry stairs to the rear egress leave no space for a landing and are beginning to crumble.

Proposed renovation will involve leveling the floor structure, replacing beadboard panel walls with standard 2x4 wall framing allowing for insulation and electrical, shifting the egress door (along the same wall) to align with the flow of traffic, replacing existing doors and windows with high-quality operable replacements that will align with the design of house, constructing a rear deck, and likely making a minor shift of the fencing along the property side to allow pedestrian passage beside the deck.

### Site plan

Mudroom exterior walls impacted by proposed work are indicated in yellow. No changes are suggested to the residence's footprint, only renovation within the existing footprint. Deck is proposed to be set back 10' from side property line as indicated in site plan. Potential shift to fence line also reflected below in blue.



## Exterior wall finishes

Exterior walls are currently only single panels of beadboard recessed behind the face of trim-clad structural posts without any framed wall cavity. Each panel is approximately 4-5' square with three such panels along the side wall and one at the back wall. Each panel has a set of two windows above.



*From left to right: rear corner view of mudroom exterior, view from back yard, view from side yard*

Structural posts are expected to remain unchanged. Each beadboard panel, however, is proposed to be replaced with typical 2x4 framing finished with drywall on the interior and siding on the exterior. For the exterior material, we propose either horizontally lapped, tongue and groove, or panel siding. In the interest of durability and given the location of this room at the rear corner of the house, we propose using a fiber cement siding material. This will replace the single panels of beadboard with properly framed and insulated walls while retaining nearly the identical appearance of the current finishes.

## Doors

Existing rear exterior doors to mudroom and basement are both beyond repair due to state of disrepair and their irregularity in size from previously being cut to match the angled pitch of the mudroom floor and a step-over drainage pipe that previously ran along the bottom of the basement door. Existing doors are also inconsistent in design elements – e.g., raised panel vs. recessed panel, third-light vs. half-light, divided vs. non-divided light – and share no resemblance to other exterior doors on the house.



*From left to right: rear exterior wall of mudroom, zoom in on rear egress door to mudroom, rear egress door to basement*



Both doors need to be replaced with properly sized, full-height doors. We will do so with coordinating doors in both locations that will add consistency of design while improving function and security. Given both doors are exposed to the elements without cover and are exclusively rear facing, in accordance with the historical district design guidelines, we propose replacing with fiberglass doors that will add durability and security while allowing us to replicate the essential design elements. Upon replacing the mudroom door, we propose slightly shifting its location along the same wall, swapping its placement with the window/panel segment to its side. This small change will allow the door to align with the interior door and improve the flow of foot traffic and usefulness of the space while making no meaningful change to the overall design of the room.

## Windows

Existing windows within the mudroom are entirely inoperable, have several broken / damaged panes, have areas with significant rot, and the type of window and design elements of these specific windows are inconsistent with the historical windows of the house, also consistent with the potential that this room was a porch that was later finished in. Notably, these windows appear to be spring balanced rather than the historical weighted windows found in the rest of the 1926 house and are also inconsistent with the muntin design and non-divided lower sashes of all other windows on the house.



*From left to right: exterior view of mudroom windows, interior view of mudroom windows*

Windows need to be removed and replaced as part of the re-framing of the mudroom exterior walls described above. Given the inoperability, disrepair, and the fact that these windows are inconsistent with the historical windows elsewhere in the house, we propose replacing with architectural grade windows customized to closely replicate the specific design elements of the original windows across the house. Specifically, we propose using the same customized Andersen windows and specs that were recently approved by the HPC and installed for our second floor in prior renovations. These windows will match the following specs of the house: double hung, equal sash, divided upper sash and non-divided lower sash,  $\frac{3}{4}$ " muntin with fully divided (separator between panes) double pane glass, wood construction, etc. Design drawings are included in the images below.




Permanent exterior  
Permanent interior  
with spacer

### FULL DIVIDED LIGHT

Permanently applied to the interior and exterior of the window, with a spacer between the glass.

### Wood Jamb Liner



### HARDWARE




Standard lock and keeper design



### Grille Bar Widths & Pattern



3/4" (19)



*Design photos for proposed windows (exact same specs as windows replaced elsewhere in house)*

## Deck

Existing entry to the rear mudroom egress door is via a set of masonry stairs with no landing at the top. Existing stairs are in disrepair and beginning to settle and come apart at mortared joints.



We propose replacing existing stairs with a rear deck off the mudroom of approximately 20'x20'. Rear door is currently ~36" above ground level, which will serve as the expected height of the deck (though higher from ground away from house according to minorly sloped grade). Deck will be set back 10' from the side property line given its height above 30". We plan to use the same materials for this deck as the other deck built last year at the property with a high grade and durable composite material for deck boards and railing (MoistureShield Meridian decking and TimberTech composite railing).



# FLOOD HAZARD STATEMENT

I HAVE THIS DATE, EXAMINED THE "FIA FLOOD HAZARD MAP" AND FOUND IN MY OPINION REFERENCED PARCEL IS NOT IN AN AREA HAVING SPECIAL FLOOD HAZARDS.

PANEL 13089C0069J

EFFECTIVE DATE: 05/16/2013

ZONE 'X'

THIS SURVEY PLAT OF EXISTING CONDITIONS ON THE PROPERTY MUST BE USED AS A SINGLE STAND ALONE DOCUMENT. IT CAN NOT BE SCANNED AND ALTERED, CROPPED OUT COPY/PASTE OR MODIFIED WITH SURVEY SYSTEMS ATLANTA TITLE BLOCK, SURVEYOR'S STAMP AND SIGNATURE. THIS SURVEY PLAT CAN BE ONLY ATTACHED AS A SEPARATE DOCUMENT BY ITSELF TO DEVELOPMENT PROJECTS AND SITE PLANS AND CAN NOT BE INSERTED WITH SURVEY SYSTEMS ATLANTA TITLE BLOCK, SURVEYOR'S STAMP AND SIGNATURE TO SOME OTHER DEVELOPMENT PROJECTS PREPARED BY ANY OTHER PARTY WITHOUT WRITTEN APPROVAL AND ORIGINAL BLUE INK SIGNATURE OF THE SURVEYOR OF RECORD.

ALL MATTERS OF TITLE ARE EXCEPTED. THIS PLAT IS SUBJECT TO ALL LEGAL EASEMENTS AND RIGHTS-OF-WAY PUBLIC OR PRIVATE. NOTE: PROPERTY LINES SHOWN ON THIS MAP/PLAT REPRESENT PHYSICAL FIELD CONDITIONS BY EVIDENCE OF APPARENT POSSESSION (IRON PINS FOUND, OLD & ESTABLISHED FENCE LINES, OLD WALL LINES, SHRUB & HEDGE LINE, HOUSE LOCATIONS, ETC.) THEY MAY DIFFER AND BE IN CONTENTION FROM EVIDENCE FOUND AT THE APPLICABLE COUNTY COURTHOUSE. THEY MAY ALSO DIFFER FROM OTHER SURVEYOR OPINIONS AND/OR NEIGHBORS SURVEYS/PLATS. A FULL LAND TITLE REPORT OPINION ON ALL PROPERTIES, INCLUDING ADJACENT AND CONTIGUOUS PROPERTIES MAY BE NEEDED TO RESOLVE ALL POSSIBLE PROPERTY LINE DISPUTES OR DISCREPANCIES. THIS MAP/PLAT WAS MADE WITHOUT THE BENEFIT OF A CURRENT TITLE COMMITMENT. EASEMENTS AND ENCUMBRANCES MAY EXIST WHICH BENEFIT AND BURDEN THIS PROPERTY. THIS MAP/PLAT IS SUBJECT TO REVISIONS AND UPDATE UPON RECEIPT OF SAID TITLE COMMITMENT. BUILDING LINES SHOWN HEREON DERIVED FROM VARIOUS ONLINE SOURCES. THEY MAY BE IN CONTENTION WITH OR DIFFER FROM INTERPRETATIONS OF GOVERNING AUTHORITIES. IT IS THE CLIENT'S OBLIGATION TO CONFIRM WITH PERMITTING AGENCIES BASED ON THEIR SPECIFIC CONSTRUCTION PROJECTS. ~ THIS MAP/PLAT HAS BEEN FIELD RUN WITH ASSUMED ELEVATIONS, THEN ADJUSTED TO NAVD 88 BASED ON MULTIPLE OBSERVATIONS FROM GOOGLE EARTH SATELLITE IMAGERY OR OTHER ONLINE SOURCES. THE ELEVATIONS SHOWN HEREON ARE +/- 1' (± ONE FOOT). TREE SYMBOLS ARE NOT TO SCALE. TREE SYMBOLS REPRESENT POSITION OF TREE & ARE NOT THE CRITICAL ROOT ZONE (NOT DRIPLINE). NOTE: ANY & ALL UNDERGROUND UTILITIES, I.E. SEWER, STORM, GAS, WATER, ETC., HAVE NOT BEEN FIELD LOCATED BY CONVENTIONAL SURVEY METHODS.

PROPERTY ADDRESS: 21 KENSINGTON RD, AVONDALE ESTATES, GA 30002

LAND AREA: 18.125 AC, 0.439 AC

INTERVIEWS: 6,250 SF, 32.7%

ZONING: R-12

PLAT PREPARED FOR: 21 KENSINGTON ROAD

LOT 8, BLOCK 18, AVONDALE ESTATES SUBDIVISION

LAND LOT 249, 15th DISTRICT, PARCEL ID: 15 249 04 024, BY: CHADLIS COUNTY, GEORGIA

RELO DATE: 02-07-2023, NH

CITY OF AVONDALE ESTATES, GA

DRAWN DATE: 02-07-2023, NE

REFERENCE: DEED BOOK 27349, PAGE 11

THE FIELD DATA UPON WHICH THIS PLAT IS BASED HAS A CLOSURE OF 1 FOOT IN 10,000 FEET, AN ANGULAR ERROR OF 1 SECOND PER ANGULAR POINT AND WAS ADJUSTED USING THE LEAST SQUARES METHOD. THIS PLAT HAS BEEN CALCULATED FOR CLOSURE AND FOUND TO BE ACCURATE TO 1 FOOT IN 30,000 FEET, AN ELECTRONIC TOTAL STATION WAS USED IN THE PREPARATION OF THIS PLAT. NO STAKE PLANE MONUMENT FOUND WITHIN 500' OF THIS PROPERTY.

THIS SURVEY WAS PREPARED IN CONFORMITY WITH THE TECHNICAL STANDARDS FOR PROPERTY SURVEYS IN GEORGIA AS SET FORTH IN CHAPTER 180-7 OF THE RULES OF THE GEORGIA BOARD OF REGISTRATION FOR PROFESSIONAL SURVEYORS AND LAND SURVEYORS AND AS SET FORTH IN THE GEORGIA PLAT ACT (O.C.G.A. 14-2-202).

SURVEY SYSTEMS ATLANTA  
880 LAKE DR. SW, DUBLIN, GA 30034  
404-450-0007, 404-450-0007  
FAX 404-450-0004, OFFICE 404-760-0010

# SURVEYOR'S CERTIFICATION

THIS PLAT IS A RETRACEMENT OF AN EXISTING PARCEL OR PARCELS OF LAND AND DOES NOT SUBDIVIDE OR CREATE A NEW PARCEL OR MAKE ANY CHANGES TO ANY REAL PROPERTY BOUNDARIES. THE RECORDING INFORMATION OF THE DOCUMENTS, MAPS, PLATS, OR OTHER INSTRUMENTS WHICH CREATED THE PARCEL OR PARCELS ARE STATES HEREON. RECORDATION OF THIS PLAT DOES NOT APPLY APPROVAL OF ANY LOCAL JURISDICTION, AVAILABILITY OF PERMITS, COMPLIANCE WITH LOCAL REGULATIONS OR REQUIREMENTS OR SUITABILITY FOR ANY USE OR PURPOSE OF THE LAND. FURTHERMORE, THE UNDERSIGNED LAND SURVEYOR CERTIFIES THAT THIS PLAT COMPLIES WITH THE MINIMUM TECHNICAL STANDARDS FOR PROPERTY SURVEYS IN GEORGIA AS SET FORTH IN THE RULES AND REGULATIONS OF THE GEORGIA BOARD OF REGULATION FOR PROFESSIONAL ENGINEERS AND LAND SURVEYORS AND AS SET FORTH IN O.C.G.A. SECTION 15-6-67

GERALD H. BERNHARD


GEORGIA RLS NO. 2688

# \* LEGEND \*

NOTE: ALL ITEMS IN THIS LEGEND MAY NOT APPEAR ON THIS PLAT.

AKA ALSO KNOWN AS  
APP AS PER DEED  
APP AS PER PLAT  
BSL BUILDING (SETBACK) LINE  
CP COMPUTED POINT  
CTP CRIMP TOP PIPE FOUND  
OTP OPEN TOP PIPE FOUND  
D DEED (BOOK/PAGE)  
DW DRIVEWAY  
EP EDGE OF PAVEMENT  
FFE FINISH FLOOR ELEVATION  
FKA FORMERLY KNOWN AS  
IPF IRON PIN FOUND  
L ARC LENGTH  
LL LAND LOT  
LLL LAND LOT LINE  
N NEIGHBOR'S

N/F NOW OR FORMERLY  
NAIL NAIL FOUND  
P PLAT (BOOK/PAGE)  
POB POINT OF BEGINNING  
POC POINT OF COMMENCEMENT  
R RADIUS LENGTH  
R/W RIGHT-OF-WAY  
RBF REINFORCING BAR FOUND  
(1/2" UNO)  
RBS 1/2" REINFORCING BAR SET  
SW SIDEWALK  
SSE SANITARY SEWER EASEMENT  
SSCO SANITARY SEWER CLEANOUT  
SSMH SANITARY SEWER MANHOLE  
-X- FENCE LINE  
CB CATCH BASIN  
SWCB STORM WATER CATCH BASIN  
WALL



ZONING NOTE:  
BEFORE DEVELOPMENT OF THIS PROPERTY, DEVELOPER AND ARCHITECT TO CONFIRM ZONING DISTRICT, PER ZONING DEPARTMENT.

PROPERTY IS ZONED R-12

BUILDING SETBACK:  
FRONT 40'  
SIDE 10'  
REAR 35'  
MAX LOT COVERAGE




IF YOU SEE GEORGIA...  
CALL US FIRST  
1-800-282-7411  
770-437-4444  
(METRO ATLANTA ONLY)  
UTILITY PROTECTION CENTER  
IT'S THE LAW

| IMPERVIOUS (IN SQUARE FEET) |      |
|-----------------------------|------|
| HOUSE                       | 1758 |
| GARAGE                      | 625  |
| AWNING                      | 254  |
| CONC. DW                    | 2046 |
| CONC. SW                    | 299  |
| PORCH                       | 191  |
| STEPS                       | 198  |
| CONC. PATIO                 | 493  |
| CONC. AREA                  | 33   |
| DECK                        | 159  |
| WALL                        | 203  |
| TOTAL IMPERVIOUS            | 6259 |

PROJECT: ROWLAND RESIDENCE  
MUDROOM RENOVATION AND DECK  
21 KENSINGTON ROAD  
AVONDALE ESTATES, GEORGIA 30002

AS BUILT  
SURVEY

C1.0



0 10' 20'  
SCALE 1" = 10'

| EXISTING IMPERVIOUS CALCULATIONS:      |           |
|----------------------------------------|-----------|
| OVERALL LAND:                          | 19,125 SF |
| 40% IMPERVIOUS =                       | 7,650 SF  |
| 2-STORY HOUSE (1 <sup>ST</sup> FLOOR): | 1,758 SF  |
| SCREENED PORCH:                        | 191 SF    |
| ENTRY STEPS / LANDINGS:                | 231 SF    |
| CONCRETE SIDEWALKS:                    | 299 SF    |
| STONE/BLOCK WALLS:                     | 203 SF    |
| DRIVEWAY AND PARKING PAD:              | 2,046 SF  |
| GARAGE/ADU AND DECK:                   | 784 SF    |
| REAR PATIO AND PAVILION:               | 747 SF    |
| TOTAL IMPERVIOUS SF:                   | 6,259 SF  |
| IMPERVIOUS % =                         | 32.7%     |

| PROPOSED SITE PLAN IMPERVIOUS CALCULATIONS: |                   |
|---------------------------------------------|-------------------|
| OVERALL LAND:                               | 19,125 SF         |
| 40% IMPERVIOUS =                            | 7,650 SF          |
| 2-STORY HOUSE (1 <sup>ST</sup> FLOOR):      | 1,758 SF          |
| SCREENED PORCH:                             | 191 SF            |
| ENTRY STEPS / LANDINGS:                     | 181 SF            |
| MAIN HOUSE REAR DECK:                       | 400 SF            |
| CONCRETE SIDEWALKS:                         | 299 SF            |
| STONE/BLOCK WALLS:                          | 203 SF            |
| DRIVEWAY AND PARKING PAD:                   | 2,046 SF          |
| GARAGE/ADU AND DECK:                        | 784 SF            |
| REAR PATIO AND PAVILION:                    | 747 SF            |
| TOTAL IMPERVIOUS SF:                        | 6,609 SF          |
| IMPERVIOUS % =                              | 34.6%             |
|                                             | (LESS THAN 40.0%) |

PROJECT:

ROWLAND RESIDENCE  
MUDROOM RENOVATION AND DECK  
21 KENSINGTON ROAD  
AVONDALE ESTATES, GEORGIA 30002

PROPOSED  
SITE PLAN

C2.0